

Brelje and Race Laboratories, Inc.

425 South E Street, Santa Rosa, CA 95404

GUIDELINES FOR DOMESTIC WATER USE

Total Hardness as CaCO₃: 0-49 is considered soft.
50-99 is considered slightly hard.
100-149 is considered moderately hard.
150 + is considered hard.

The recommended range for Total Hardness as CaCO₃ is 60-120.

Specific Conductance: The recommended range is less than 900 μ mhos/cm.

pH : The recommended range is 6.8 – 8.2.

Nitrate as N: The required limit for Nitrate as N in drinking water is 10 mg/L.

Iron: The recommended limit of Iron is 300 μ g/L.

Manganese: The recommended limit for Manganese is 50 μ g/L.

Arsenic: The required limit for Arsenic is 10 μ g/L.