

# Brelje and Race Laboratories, Inc.

425 South E Street, Santa Rosa, CA 95404  
707-544-8807

## GUIDELINES FOR DOMESTIC WATER USE

Nitrate as N:	The <u>required</u> limit for Nitrate as N in drinking water is 10 mg/L.
Iron:	The <u>recommended</u> limit for Iron is 300 $\mu$ g/L.
Manganese:	The <u>recommended</u> limit for Manganese is 50 $\mu$ g/L.
Total Hardness as CaCO <sub>3</sub> :	0-49 is considered soft. 50-99 is considered slightly hard. 100-149 is considered moderately hard. 150+ is considered hard.
Arsenic: $\mu$ g/L.	The <u>required</u> limit for Arsenic in drinking water is 10 $\mu$ g/L.